

**GOVERNMENT OF ANDHRA PRADESH  
ELECTRICAL INSPECTORATE**

TO: ELECTRICAL INSPECTOR,  
No. 2, SECTOR 10,  
P. COLONY,  
VISAKHAPATNAM.

TO:  
M/S DIET,  
ANKAPALLI,  
VISAKHAPATNAM,  
VISAKHAPATNAM DISTRICT.

8/10/08

Lr.No. EI/VSP/TECH/HT/759/VSP/D. No: 1870/08 Dated:06-10-2008

Sub:- The Electricity Act 2003 and the Indian Electricity Rules 1956. H.V. Electrical Installation of M/S DIET, ANAKAPALLI, VISAKHAPATNAM DISTRICT - Statutory Approval under Rule 63(2) & section 54 of Electricity Act 2003 - Accorded.

- Ref:-1. This office Lr.No.EI/VSP/TECH/759/VSP/D.No: 1453/08 Dated: 12-08-2008  
2. Inspection dated: 24-09-2008  
3. This office Lr.No.EI/VSP/TECH/759/VSP/D.No: Camp/08 Dated: 24-09-2008  
4. Your Compliance report received on: 06-10-2008

Under section 54 read with Rule 63(2) of Indian Electricity Rules 1956, the following items of your H.T. Electrical Installation are approved for energisation.


| Sl. No | Particulars of Equipment | Make            | Makers' Serial Number | Capacity     | Voltage     |
|--------|--------------------------|-----------------|-----------------------|--------------|-------------|
| 1.     | TRANSFORMER              | SAI TECK        | 18/160/08             | 160 K.V.A.,  | 11000/433 V |
| 2.     | GENERATOR                | POWERICA        | 01PSM1/08/07/04725    | 125 K.V.A.,  | 415 VOLTS   |
| 3.     | M.V.LOAD                 |                 |                       | 48.5 H.P.,   | 415 VOLTS   |
|        | 1. MOTORS (A.C)          | AS PER ANNEXURE | AS PER ANNEXURE       | 79.5 K.V.A., | 415 VOLTS   |
|        | 2. U.P.S.                | AS PER ANNEXURE | AS PER ANNEXURE       | 30 H.P.,     | 415 VOLTS   |
|        | 3. MOTORS (D.C.)         | AS PER ANNEXURE | AS PER ANNEXURE       | 40 K.V.A.R., | 415 VOLTS   |
|        | 4. CAPACITORS            | AS PER ANNEXURE | AS PER ANNEXURE       |              |             |
| 4.     | L.V.LOAD                 |                 |                       | 6.5 H.P.,    | 220 VOLTS   |
|        | 1. MOTORS                | AS PER ANNEXURE | AS PER ANNEXURE       | 57.1.W.,     | 220 VOLTS   |
| 5.     | LIGHTING LOAD            | AS PER ANNEXURE | AS PER ANNEXURE       |              |             |

Under Rule 63(3) of Indian Electricity Rules 1956, any additions or alterations to your above Electrical Installation shall not be connected to supply until and unless the same are approved in writing by this office.

Under Rule 30(4) and 46(3) of Indian Electricity Rules 1956, you are at all times be solely responsible for the maintenance of the above installation in such condition as to be free from danger.

The original manufacturers' test certificates of Transformer, A.B. Switch, Lightning Arrestors are accepted and returned here with.

*Handwritten notes:*  
- 160kva - 12.50  
- 26338 - 100  
- 61.98kw - 2.50

Yours faithfully,  
  
ELECTRICAL INSPECTOR,  
VISAKHAPATNAM.

- Encl: 1. Load list  
2. Test Certificates

1. Copy to the Divisional Engineer/ Operation/E.P.D.C.L of A.P/ANAKAPALLI for information. The date of release of supply to the above H.T. Installation may be intimated to the Deputy Electrical Inspector, VISAKHAPATNAM Sub-Division.

2. Copy to the Deputy Electrical Inspector, VISAKHAPATNAM Sub-Division.